

# Zone Report

Report Date: 28/11/2019

---

M499000101 MULTICOM 4 PLUS99 AREA 99 Template

Zone No	Module No	Description
0	755	MULTICOM POLL DELAY
64000	755	EVENT NOT DEFINED
0	756	MULTICOM POLL FAIL
64000	756	EVENT NOT DEFINED
0	927	MULTICOM GPRS REMOTE SYSTEM UPDATE STARTED
64000	927	EVENT NOT DEFINED
0	928	MULTICOM GPRS REMOTE SYSTEM UPDATE STARTED
64000	928	EVENT NOT DEFINED
900	950	MULTICOM EXTERNAL TAMPER
901	950	MULTICOM INPUT1
902	950	MULTICOM INPUT2
903	950	MULTICOM INPUT3
904	950	MULTICOM INPUT4
905	950	MULTICOM PSTN VOLTAGE
906	950	MULTICOM BACKUP BATTERY
907	950	MULTICOM GSM CONNECTION
908	950	MULTICOM GPRS CONNECTION
909	950	MULTICOM ETHERNET CONNECTION
910	950	MULTICOM MAINS POWER
911	950	MULTICOM PERIODIC TEST SIGNAL
912	950	MULTICOM UNABLE TO POLL
913	950	MULTICOM REMOTE SOFTWARE UPDATE
914	950	MULTICOM ALARM BUFFER OVERFLOW SIGNALS MAY BE LOST
915	950	MULTICOM UNABLE TO COMMUNICATE SOME ALARM EVENTS
916	950	MULTICOM SERVICE REQUIRED
917	950	MULTICOM ONE OR MORE ZONES LOCKED OUT
918	950	MULTICOM CYCLING THE MULTICOM POWER POINT
919	950	MULTICOM POWER
920	950	MULTICOM PSTN COMMS WATCH
64000	950	EVENT NOT DEFINED
0	1755	MULTICOM POLL DELAY
64000	1755	EVENT NOT DEFINED
0	1756	MULTICOM POLL FAIL
64000	1756	EVENT NOT DEFINED
900	1950	MULTICOM EXTERNAL TAMPER

901	1950 MULTICOM INPUT1
902	1950 MULTICOM INPUT2
903	1950 MULTICOM INPUT3
904	1950 MULTICOM INPUT4
905	1950 MULTICOM PSTN VOLTAGE
906	1950 MULTICOM BACKUP BATTERY
907	1950 MULTICOM GSM CONNECTION
908	1950 MULTICOM GPRS CONNECTION
909	1950 MULTICOM ETHERNET CONNECTION
910	1950 MULTICOM MAINS POWER
911	1950 MULTICOM PERIODIC TEST SIGNAL
912	1950 MULTICOM UNABLE TO POLL
913	1950 MULTICOM REMOTE SOFTWARE UPDATE
914	1950 MULTICOM ALARM BUFFER OVERFLOW SIGNALS MAY BE LOST
915	1950 MULTICOM UNABLE TO COMMUNICATE SOME ALARM EVENTS
916	1950 MULTICOM SERVICE REQUIRED
917	1950 MULTICOM ONE OR MORE ZONES LOCKED OUT
918	1950 MULTICOM CYCLING THE MULTICOM POWER POINT
919	1950 MULTICOM POWER
920	1950 MULTICOM PSTN COMMS WATCH
64000	1950 EVENT NOT DEFINED
0	2755 MULTICOM POLL DELAY
64000	2755 EVENT NOT DEFINED
0	2756 MULTICOM POLL FAIL
64000	2756 EVENT NOT DEFINED
900	2950 MULTICOM EXTERNAL TAMPER
901	2950 MULTICOM INPUT1
902	2950 MULTICOM INPUT2
903	2950 MULTICOM INPUT3
904	2950 MULTICOM INPUT4
905	2950 MULTICOM PSTN VOLTAGE
906	2950 MULTICOM BACKUP BATTERY
907	2950 MULTICOM GSM CONNECTION
908	2950 MULTICOM GPRS CONNECTION
909	2950 MULTICOM ETHERNET CONNECTION
910	2950 MULTICOM MAINS POWER
911	2950 MULTICOM PERIODIC TEST SIGNAL
912	2950 MULTICOM UNABLE TO POLL
913	2950 MULTICOM REMOTE SOFTWARE UPDATE
914	2950 MULTICOM ALARM BUFFER OVERFLOW SIGNALS MAY BE LOST
915	2950 MULTICOM UNABLE TO COMMUNICATE SOME ALARM EVENTS
916	2950 MULTICOM SERVICE REQUIRED
917	2950 MULTICOM ONE OR MORE ZONES LOCKED OUT
918	2950 MULTICOM CYCLING THE MULTICOM POWER POINT
919	2950 MULTICOM POWER
920	2950 MULTICOM PSTN COMMS WATCH
64000	2950 EVENT NOT DEFINED

