

Type Report

Report Date: 28/11/2019

CARK000101 CARDAX-K Template

Type No	Description	Action Plan
121	ALARM	Medical Alarm
130	ALARM	General Alarm
140	CONTROLLER GENERAL ALARM	General Alarm
143	EXPANSION FAILURE	System Alert
145	TAMPER	System Alert
302	CONTROLLER POWER OUT OF RANGE	Low Battery
305	CONTROLLER MAINS POWER	Low Battery
330	CONTROLLER SYSTEM PERIPHERAL	Low Battery
341	EXPANSION ENCRYPTION TAMPER	Low Battery
350	CONTROLLER DIAL UP	Low Battery
393	CONTROLLER MAINTENANCE WARNING	Low Battery
400	WITH CARDAX CARD	Opening (Unset), No Alarm
401	WITH CARDAX CARD	Opening (Unset), No Alarm
402	WITH CARDAX CARD	Opening (Unset), No Alarm
423	DOOR FORCED	System Alert
426	DOOR NOT LOCKED OR OPEN TO LONG	System Alert
461	EXPANSION WRONG CODE	System Alert
570	BYPASS	Zone Bypass
602	PERIODIC TEST SIGNAL	System Alarm
1121	RESTORE	Restoral, No Alarm
1130	RESTORE	Restoral, No Alarm
1140	CONTROLLER GENERAL ALARM	Restoral, No Alarm
1143	EXPANSION FAILURE	Restoral, No Alarm
1145	TAMPER	Restoral, No Alarm
1302	CONTROLLER POWER OUT OF RANGE	Restoral, No Alarm
1305	CONTROLLER MAINS POWER	Restoral, No Alarm
1330	CONTROLLER SYSTEM PERIPHERAL	Restoral, No Alarm
1341	EXPANSION ENCRYPTION TAMPER	Restoral, No Alarm
1350	CONTROLLER DIAL UP	Restoral, No Alarm
1393	CONTROLLER MAINTENANCE WARNING	Restoral, No Alarm
1400	WITH CARDAX CARD	Closing (Set), No Alarm

1401	WITH CARDAX CARD	Closing (Set), No Alarm
1402	WITH CARDAX CARD	Closing (Set), No Alarm
1423	DOOR FORCED	Restoral, No Alarm
1426	DOOR NOT LOCKED OR OPEN TO LONG	Restoral, No Alarm
1461	EXPANSION WRONG CODE	Restoral, No Alarm
1570	UN-BYPASS	Zone Bypass