

Type Report

Report Date: 18/03/2021

PACO000101 PACOM Template

Type No	Description	Action Plan
110	External fire alarm	General Alarm
120	External raid alarm	General Alarm
121	External duress alarm	General Alarm
130	External normal alarm	General Alarm
132	External vault alarm	General Alarm
307	External alarm zone failed self test	General Alarm
354	External alarm zone test report overdue	General Alarm
380	External trouble alarm	General Alarm
383	External tamper alarm	General Alarm
384	External spread-spectrum transmitter bat	General Alarm
388	External alarm zone range reduction alar	General Alarm
391	External alarm zone anti-masking alarm	General Alarm
401	Open by user (day mode)	Opening (Unset), No Alarm
402	Area open by user	Opening (Unset), No Alarm
422	Duress open by user (day mode)	Opening (Unset), No Alarm
423	Forced door alarm	General Alarm
426	Door ajar	General Alarm
430	Late working on premises	General Alarm
431	Late working in vault	General Alarm
432	Extended late working to all night	General Alarm
457	Exit error	General Alarm
458	User on premises (combined with other mo	General Alarm
459	Recent close	General Alarm
570	External isolate (bypass/shunt)	General Alarm
574	External alarm zone isolated by mode cha	General Alarm
602	External alarm zone tested	General Alarm
700	External unsupported alarm type	General Alarm
810	External supervisory fire alarm	General Alarm
820	External environmental normal alarm	General Alarm
823	Forced door supervisory alarm	General Alarm
826	Door ajar supervisory	General Alarm

830	External supervisory normal alarm	General Alarm
1401	Close by user (night mode)	Closing (Set), No Alarm
1402	Area close by user	Closing (Set), No Alarm
1422	Duress close by user (night mode)	Closing (Set), No Alarm
1570	External deisolate	General Alarm